

Cable ID	Summary	Test Standard	Length	Headroom	Date / Time
MDF-F-01	PASS	TIA 568B Fiber FTA410/20	335 (ft)	0.72 dB	09/20/2005 04:02pm
MDF-F-02	PASS	TIA 568B Fiber FTA410/20	335 (ft)	1.13 dB	09/20/2005 04:02pm
MDF-F-03	PASS	TIA 568B Fiber FTA410/20	335 (ft)	1.09 dB	09/20/2005 04:04pm
MDF-F-04	PASS	TIA 568B Fiber FTA410/20	335 (ft)	0.73 dB	09/20/2005 04:04pm
MDF-F-05	PASS	TIA 568B Fiber FTA410/20	335 (ft)	0.54 dB	09/20/2005 04:05pm
MDF-F-06	PASS	TIA 568B Fiber FTA410/20	335 (ft)	0.32 dB	09/20/2005 04:05pm
MDF-N-01	PASS	TIA 568B Fiber FTA410/20	460 (ft)	0.79 dB	09/20/2005 04:28pm
MDF-N-02	PASS	TIA 568B Fiber FTA410/20	460 (ft)	1.09 dB	09/20/2005 04:28pm
MDF-N-03	PASS	TIA 568B Fiber FTA410/20	460 (ft)	1.10 dB	09/20/2005 04:29pm
MDF-N-04	FAIL	TIA 568B Fiber FTA410/20	460 (ft)	-1.04 dB	09/20/2005 04:29pm
MDF-N-05	FAIL	TIA 568B Fiber FTA410/20	461 (ft)	-0.80 dB	09/20/2005 04:30pm
MDF-N-06	PASS	TIA 568B Fiber FTA410/20	461 (ft)	0.56 dB	09/20/2005 04:30pm
MDF-R3-01	PASS	TIA 568B Fiber FTA410/20	363 (ft)	1.31 dB	09/20/2005 04:12pm
MDF-R3-02	PASS	TIA 568B Fiber FTA410/20	363 (ft)	0.61 dB	09/20/2005 04:12pm
MDF-R3-03	FAIL	TIA 568B Fiber FTA410/20	363 (ft)	-0.09 dB	09/20/2005 04:13pm
MDF-R3-04	PASS	TIA 568B Fiber FTA410/20	363 (ft)	0.41 dB	09/20/2005 04:13pm
MDF-R3-05	FAIL	TIA 568B Fiber FTA410/20	366 (ft)	-5.63 dB	09/20/2005 04:23pm
MDF-R3-06	FAIL	TIA 568B Fiber FTA410/20	366 (ft)	-6.15 dB	09/20/2005 04:23pm

Total Length:	6956 ft
Number of Reports:	18
Number of Passing Reports:	13
Number of Failing Reports:	5
Number of Warning Reports:	0