

Cable ID	Summary	Test Standard	Length	Headroom	Date / Time
ADMIN-17	PASS	TIA Cat 6 Perm. Link	150 (ft)	5.6 dB	09/20/2005 10:11am
ADMIN-18	FAIL	TIA Cat 6 Perm. Link	148 (ft)	-2.9 dB	09/20/2005 10:13am
ADMIN-19	PASS	TIA Cat 6 Perm. Link	150 (ft)	4.8 dB	09/20/2005 10:12am
ADMIN-20	PASS	TIA Cat 6 Perm. Link	148 (ft)	6.1 dB	09/20/2005 10:18am
ADMIN-21	PASS	TIA Cat 6 Perm. Link	149 (ft)	1.2 dB	09/20/2005 10:17am
ADMIN-22	PASS	TIA Cat 6 Perm. Link	142 (ft)	2.7 dB	09/20/2005 10:19am
ADMIN-23	PASS	TIA Cat 6 Perm. Link	143 (ft)	4.2 dB	09/20/2005 10:18am
ADMIN-01	FAIL	TIA Cat 6 Perm. Link	238 (ft)	-0.3 dB	09/20/2005 10:08am
ADMIN-02	FAIL	TIA Cat 6 Perm. Link	236 (ft)	3.7 dB	09/20/2005 10:08am
ADMIN-03	FAIL	TIA Cat 6 Perm. Link	236 (ft)	4.5 dB	09/20/2005 10:06am
ADMIN-04	PASS	TIA Cat 6 Perm. Link	237 (ft)	6.6 dB	09/20/2005 10:05am
ADMIN-05	FAIL	TIA Cat 6 Perm. Link	236 (ft)	2.9 dB	09/20/2005 12:00pm
ADMIN-06	PASS	TIA Cat 6 Perm. Link	190 (ft)	4.1 dB	09/20/2005 10:03am
ADMIN-07	PASS	TIA Cat 6 Perm. Link	190 (ft)	6.0 dB	09/20/2005 10:04am
ADMIN-08	PASS	TIA Cat 6 Perm. Link	159 (ft)	2.2 dB	09/20/2005 10:16am
ADMIN-09	PASS	TIA Cat 6 Perm. Link	161 (ft)	4.6 dB	09/20/2005 10:16am
ADMIN-10	PASS	TIA Cat 6 Perm. Link	160 (ft)	3.3 dB	09/20/2005 10:15am
ADMIN-11	PASS	TIA Cat 6 Perm. Link	159 (ft)	0.5 dB	09/20/2005 10:14am
ADMIN-14	PASS	TIA Cat 6 Perm. Link	187 (ft)	2.9 dB	09/20/2005 10:09am
ADMIN-15	PASS	TIA Cat 6 Perm. Link	195 (ft)	0.9 dB	09/20/2005 10:10am
ADMIN-16	PASS	TIA Cat 6 Perm. Link	150 (ft)	6.3 dB	09/20/2005 10:11am
ADMIN-24	PASS	TIA Cat 6 Perm. Link	135 (ft)	4.6 dB	09/20/2005 10:19am
ADMIN-25	PASS	TIA Cat 6 Perm. Link	134 (ft)	3.3 dB	09/20/2005 10:20am
ADMIN-26	PASS	TIA Cat 6 Perm. Link	128 (ft)	4.0 dB	09/20/2005 10:21am
ADMIN-27	PASS	TIA Cat 6 Perm. Link	128 (ft)	4.7 dB	09/20/2005 10:21am
ADMIN-28	PASS	TIA Cat 6 Perm. Link	113 (ft)	5.3 dB	09/20/2005 10:22am
ADMIN-29	PASS	TIA Cat 6 Perm. Link	115 (ft)	5.9 dB	09/20/2005 10:22am
ADMIN-30	PASS	TIA Cat 6 Perm. Link	90 (ft)	4.5 dB	09/20/2005 10:28am
ADMIN-31	PASS	TIA Cat 6 Perm. Link	90 (ft)	6.2 dB	09/20/2005 10:29am
ADMIN-33	PASS	TIA Cat 6 Perm. Link	94 (ft)	4.1 dB	09/20/2005 10:27am
ADMIN-34	PASS	TIA Cat 6 Perm. Link	94 (ft)	5.1 dB	09/20/2005 10:28am
ADMIN-36	PASS	TIA Cat 6 Perm. Link	105 (ft)	5.4 dB	09/20/2005 12:18pm
ADMIN-37	FAIL	TIA Cat 6 Perm. Link	56 (ft)	4.8 dB	09/20/2005 11:54am
ADMIN-38	PASS	TIA Cat 6 Perm. Link	79 (ft)	3.8 dB	09/20/2005 09:53am
ADMIN-39	PASS	TIA Cat 6 Perm. Link	82 (ft)	4.1 dB	09/20/2005 09:47am
ADMIN-40	PASS	TIA Cat 6 Perm. Link	108 (ft)	4.9 dB	09/20/2005 09:48am
ADMIN-41	PASS	TIA Cat 6 Perm. Link	81 (ft)	1.2 dB	09/20/2005 09:45am
ADMIN-42	PASS	TIA Cat 6 Perm. Link	107 (ft)	6.8 dB	09/20/2005 09:48am
ADMIN-43	PASS	TIA Cat 6 Perm. Link	83 (ft)	5.4 dB	09/20/2005 09:50am
ADMIN-44	PASS	TIA Cat 6 Perm. Link	82 (ft)	3.4 dB	09/20/2005 09:49am
ADMIN-45	PASS	TIA Cat 6 Perm. Link	77 (ft)	4.1 dB	09/20/2005 09:50am
ADMIN-46	PASS	TIA Cat 6 Perm. Link	66 (ft)	5.9 dB	09/20/2005 09:57am
ADMIN-50	PASS	TIA Cat 6 Perm. Link	66 (ft)	0.6 dB	09/20/2005 09:55am
ADMIN-54	PASS	TIA Cat 6 Perm. Link	50 (ft)	1.4 dB	09/20/2005 09:58am
ADMIN-56	PASS	TIA Cat 6 Perm. Link	111 (ft)	4.0 dB	09/20/2005 10:35am
ADMIN-58	PASS	TIA Cat 6 Perm. Link	103 (ft)	3.8 dB	09/20/2005 10:37am
ADMIN-59	PASS	TIA Cat 6 Perm. Link	100 (ft)	5.5 dB	09/20/2005 10:37am
ADMIN-62	PASS	TIA Cat 6 Perm. Link	51 (ft)	0.8 dB	09/20/2005 11:52am
ADMIN-64	PASS	TIA Cat 6 Perm. Link	92 (ft)	5.5 dB	09/20/2005 10:00am
ADMIN-66	PASS	TIA Cat 6 Perm. Link	92 (ft)	4.6 dB	09/20/2005 10:00am
ADMIN-68	PASS	TIA Cat 6 Perm. Link	123 (ft)	5.6 dB	09/20/2005 10:01am
ADMIN-69	PASS	TIA Cat 6 Perm. Link	123 (ft)	4.0 dB	09/20/2005 10:02am
ADMIN-70	PASS	TIA Cat 6 Perm. Link	126 (ft)	5.4 dB	09/20/2005 12:16pm
ADMIN-73	PASS	TIA Cat 6 Perm. Link	128 (ft)	4.9 dB	09/20/2005 10:26am
ADMIN-74	PASS	TIA Cat 6 Perm. Link	128 (ft)	3.0 dB	09/20/2005 10:26am

Total Length:	7104 ft
Number of Reports:	55
Number of Passing Reports:	49
Number of Failing Reports:	6
Number of Warning Reports:	0